



U.S. Patent No. 6,951,619

Permanent Pool Volume = 20,066 litres  
 The Hydroguard must be cleaned after the construction period if it is used as a sediment and erosion control measure  
 The Hydroguard should be inspected once per year for stabilized sites  
 Inspection will determine the maintenance frequency (annual maintenance or once every two years typical for stabilized sites)  
 Sites with unstable conditions (exposed soil or materials storage) will require more frequent inspection and maintenance

Canadian Infrastructure Products  
 Phone: (519) 212-9161  
 Web: www.c-i-p.ca

Hydroworks, LLC  
 Phone: 888-290-7900 Fax: 888-783-7271  
 Web: www.hydroworks.com

Hydroworks HG10 (3000mmØ)
PROJECT: XXX
LOCATION: XXX
DATE: XXX

