



U.S. Patent No. 6,951,619

Permanent Pool Volume = 35,168 Litres
 The Hydroguard must be cleaned after the construction period if it is used as a sediment and erosion control measure
 The Hydroguard should be inspected once per year for stabilized sites
 Inspection will determine the maintenance frequency (annual maintenance or once every two years typical for stabilized sites)
 Sites with unstable conditions (exposed soil or materials storage) will require more frequent inspection and maintenance

Hydroworks, LLC
 Phone: 888-290-7900 Fax: 888-783-7271
 Web: www.hydroworks.com

Hydroguard HG12 (3600mmØ)	
PROJECT:	XXX
LOCATION:	XXX
DATE:	XXX

